



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

### Ex COMPONENT CERTIFICATE

Certificate No.: **IECEX ITA 08.0012U**

Page 1 of 5

Certificate history:

Status: **Current**

Issue No: 2

[Issue 1 \(2012-02-10\)](#)  
[Issue 0 \(2008-09-29\)](#)

Date of Issue: 2021-08-18

Applicant: **Nautitech Mining Systems P/L**  
Unit 3, 9 Packard Ave  
Castle Hill, NSW 2154  
**Australia**

Ex Component: NTMS Shunt Types 5006-01, 5006-02 & 5006-03

*This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).*

Type of Protection: **Intrinsic Safety "ia"**

Marking: [Ex ia] I, IIC, IECEx ITA 08.0012U

Approved for issue on behalf of the IECEx  
Certification Body:

**Ajay Maira**

Position:

**Certification Authority**

Signature:  
(for printed version)

*Ajay Maira*

Date:

2021-08-18

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**Ex Testing and Certification Pty Ltd**  
1/30 Kennington Drive  
Tomago NSW 2322  
Australia



TESTING & CERTIFICATION



# IECEX Certificate of Conformity

Certificate No.: **IECEX ITA 08.0012U**

Page 2 of 5

Date of issue: 2021-08-18

Issue No: 2

Manufacturer: **Nautitech Mining Systems P/L**  
Unit 3, 9 Packard Ave  
Castle Hill, NSW 2154  
**Australia**

Additional  
manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2004** Electrical apparatus for explosive gas atmospheres - Part 0: General requirements  
Edition:4.0

**IEC 60079-11:2006** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I"  
Edition:5

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

[AU/ITA/ExTR08.0018/00](#)

[AU/ITA/ExTR08.0018/01](#)

Quality Assessment Report:

[AU/MSQ/QAR21.0001/00](#)



# IECEX Certificate of Conformity

Certificate No.: **IECEX ITA 08.0012U**

Page 3 of 5

Date of issue: 2021-08-18

Issue No: 2

**Ex Component(s) covered by this certificate is described below:**

The NTMS Shunt Type: 5006-01 is designed to restrict the transfer of energy from unspecified non-hazardous area equipment to the hazardous area circuits by limitation of voltage and current.

Rated at 12V - 50mA

The equipment comprises of electronic components mounted on a double sided printed wiring board all encapsulated within a plastic enclosure. External connections are made via solder pins located in the base of the equipment.

See Annex for further details.

**SCHEDULE OF LIMITATIONS:**

See Annexe for details



# IECEX Certificate of Conformity

Certificate No.: **IECEX ITA 08.0012U**

Page 4 of 5

Date of issue: 2021-08-18

Issue No: 2

**DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)**  
See Annexe for details.



# IECEX Certificate of Conformity

Certificate No.: **IECEX ITA 08.0012U**

Page 5 of 5

Date of issue: 2021-08-18

Issue No: 2

**Additional information:**

Job 21105

**Annex:**

[IECEX ITA 08.0012U-2 Annexe final.pdf](#)

# IECEX Certificate of Conformity



## Annexe



Annexe for Certificate No.:

IECEX ITA 08.0012U

Issue No.: 2

### Description:

As provided in 'Equipment' section of the certificate.

### Schedule of Limitations pertaining to Issue 0 of this Certificate:

These have been consolidated into the Schedule of Limitations in Issue 1 of this certificate.

### Drawing list pertaining to Issue 0 of this Certificate:

#### Manufacturer's Documents

Title:	Drawing No.:	Pages	Rev. Level:	Date:
NTMS Shunt – Assembly	ExMD500602	1	1.0	2008-08-24
NTMS Shunt Device Markings	ExMK500601	1	1.0	2008-08-24
NTMS Shunt	ExPB500601-03	1	1.0	2008-08-24
NTMS Shunt	ExPS500601-03	1	1.0	2008-08-24
NTMS Shunt Wiring Diagram	ExWD500601	1	1.0	2008-08-24

### Variations permitted by Issue 1 of this certificate:

1. Change of address, was Unit 55, 4 Hoyle Ave., Castle Hill
2. Two new types have been introduced: Types 5006-02 (Dual channel) and 5006-03 (Single channel) to form the complete set of barriers:  
  
5006-01 Rated at 12V - 50mA (-20°C to + 40°C)  
  
5006-02 Rated at 10V – 50mA (-20°C to + 60°C)  
  
5006-03 Rated at 10V – 50mA (-20°C to + 60°C) (Single channel only)
3. The PCB remained the same, only component values changed.
4. Label details were updated for the relevant changes.

# IECEX Certificate of Conformity



## Annexe



Annexe for Certificate No.:

IECEX ITA 08.0012U

Issue No.: 2

### Schedule of Limitations pertaining to Issue 1 of this certificate:

#### **NTMS Shunt Type: 5006-01**

##### Non Hazardous Area Terminals

JP2 Pins 1 & 2 with respect to earth (pins JP3 pins 1, 2 & 3)

$$U_m = 250V$$

##### Hazardous Area Terminals

#### **Single Channel with respect to earth**

JP1 pin 1 with respect to earth (pins JP3 pins 1, 2 & 3)

JP1 pin 2 with respect to earth (pins JP3 pins 1, 2 & 3)

U <sub>o</sub>	12.6V
I <sub>o</sub>	132.7mA
P <sub>o</sub>	418mW
C <sub>i</sub>	Negligible
L <sub>i</sub>	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to either hazardous area JP1 pin 1 OR JP1 pin 2 with respect to earth (pins JP3 pins 1, 2 & 3) must not exceed the following values;

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / Ω)
IIC	1.15	2.02 85
IIIB	7.40	8.08 340
IIA	27.00	16.16 680
I	29.00	26.52 1116

#### **Both Channels in parallel with respect to earth**

JP1 pins 1 & 2 with respect to earth (JP3 pins 1, 2 & 3)

U <sub>o</sub>	12.6V
I <sub>o</sub>	265.4mA
P <sub>o</sub>	835.6mW
C <sub>i</sub>	Negligible
L <sub>i</sub>	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to the hazardous area JP1 pins 1 & 2 with respect to earth (pins JP3 pins 1, 2 & 3) must not exceed the following values;

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / Ω)
IIC	1.15	0.5 42
IIIB	7.40	2.0 170
IIA	27.00	4.0 340
I	29.00	6.6 558

# IECEx Certificate of Conformity



## Annexe



Annexe for Certificate No.:

IECEx ITA 08.0012U

Issue No.: 2

### Both Channels in series no earth connection

JP1 pin 1 with respect to JP1 pin 2

U <sub>o</sub>	14.1V
I <sub>o</sub>	74.3mA
P <sub>o</sub>	262mW
C <sub>i</sub>	Negligible
L <sub>i</sub>	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to the hazardous area JP1 pin 1 with respect to JP1 pin 2 must not exceed the following values;

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / Ω)
IIC	0.71	6.44 135
IIIB	4.49	25.76 543
IIA	16.70	51.52 1087
I	19.70	84.53 1783

The above load parameters apply where;

1. The external circuit contains no combined lumped inductance (Li) or lumped capacitance (Ci) greater than 1% of the above values. OR
2. The external circuit contains either only lumped inductance (Li) or lumped capacitance (Ci) in combination with a cable. OR
3. The inductance and capacitance are distributed as in a cable.

In all other situations e.g. the external circuit contains combined lumped inductance and capacitance, up to 50% of each of the inductance and capacitance values are allowed.

The equipment must be installed within a suitable enclosure offering a degree of protection not less than IP20.

JP3 pins 1, 2 & 3 must be infallibly connected to the main system earth in an earth reference system or infallibly connected to the secondary circuit 0V node in a galvanically isolated power supply system.

### NTMS Shunt Type: 5006-02 & 5006-03

#### Non Hazardous Area Terminals

JP2 Pins 1 & 2 with respect to earth (pins JP3 pins 1, 2 & 3)

$$U_m = 250V$$



# IECEx Certificate of Conformity



## Annexe



Annexe for Certificate No.:

IECEx ITA 08.0012U

Issue No.: 2

### Hazardous Area Terminals

#### **Single Channel with respect to earth (5006-02 and 5006-03)**

**5006-02:** JP1 pin 1 OR pin 2 with respect to earth (pins JP3 pins 1, 2 & 3)

**5006-03:** JP1 pin 2 with respect to JP1 pin 1 AND earth (pins JP3 pins 1, 2 & 3)

Uo	10.5V
Io	111mA
Po	290mW
Ci	Negligible
Li	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to

- **5006-02:** either hazardous area JP1 pin 1 OR pin 2 with respect to earth (pins JP3 pins 1, 2 & 3)
- **5006-03:** JP1 pin 2 with respect to JP1 pin 1 AND earth (pins JP3 pins 1, 2 & 3) must not exceed the following values:

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / $\Omega$ )
IIC	2.41	2.88
IIIB	16.8	11.5
IIA	75.0	23.0
I	66.0	37.8

#### **Both Channels in parallel with respect to earth (5006-02)**

JP1 pins 1 & 2 with respect to earth (JP3 pins 1, 2 & 3)

Uo	10.5V
Io	222mA
Po	580mW
Ci	Negligible
Li	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to hazardous area JP1 pin 1 & 2 with respect to earth (pins JP3 pins 1, 2 & 3) must not exceed the following values:

# IECEX Certificate of Conformity



## Annexe



Annexe for Certificate No.:

IECEX ITA 08.0012U

Issue No.: 2

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / Ω)
IIC	2.41	0.72 61.2
IIIB	16.8	2.88 245
IIA	75.0	5.77 490
I	66.0	9.46 804

### Both Channels in series no earth connection (5006-02)

JP1 pin 1 with respect to JP1 pin 2

U <sub>o</sub>	12V
I <sub>o</sub>	63.2mA
P <sub>o</sub>	190mW
C <sub>i</sub>	Negligible
L <sub>i</sub>	Negligible

The capacitance and either the inductance or the inductance to resistance (L/R) ratio of the hazardous area load connected to hazardous area JP1 pin 1 with respect to JP1 pin 2 must not exceed the following values:

Group	Capacitance (uF)	Inductance (mH) OR L/R Ratio (uH / Ω)
IIC	1.41	8.9 187
IIIB	9.0	35.6 750
IIA	36.0	71.2 1501
I	35.0	116.8 2462

The above load parameters apply where:

1. The external circuit contains no combined lumped inductance (Li) or lumped capacitance (Ci) greater than 1% of the above values. OR
2. The external circuit contains either only lumped inductance (Li) or lumped capacitance (Ci) in combination with a cable. OR
3. The inductance and capacitance are distributed as in a cable.

In all other situations e.g. the external circuit contains combined lumped inductance and capacitance, up to 50% of each of the inductance and capacitance values are allowed.

The equipment must be installed within a suitable enclosure offering a degree of protection not less than IP20.

# IECEX Certificate of Conformity



## Annexe



**Annexe for Certificate No.:**

**IECEX ITA 08.0012U**

**Issue No.:**

**2**

In earth reference systems the JP3 pins 1, 2 & 3 must be infallibly connected to the main system earth in an earth reference system or infallibly connected to the secondary circuit 0 V node in a galvanically isolated power supply system.

### Drawings Associated with the Issue 1 of this Certificate:

#### **Manufacturer's Documents**

Title:	Drawing No.:	Pages	Rev. Level:	Date:
NTMS Shunt - Assembly	ExMD500602	1	3.0	2012-01-12
Device Markings	ExMK500601	1	5	2012-01-10
NTMS Shunt	ExPB500601-03	1	2.0	2012-01-12
NTMS Shunt Wiring Diagram	ExWD500601	1	2	2011-12-09**
IS Barrier – dual channel – 60 Deg.C	ExSH500602-A	1	1	2011-12-09
IS Barrier – single channel – 60 Deg.C	ExSH500603-A	1	2	2011-12-09

\*\* The drawing date listed was incorrect. Corrected during Issue 2 of this certificate.

### Variations permitted by Issue 2 of this certificate:

- The manufacturer's Quality Assessment was changed from Ex Testing and Certification to another IECEX Certification Body, Mine Safety Technology Centre. QAR reference has been changed accordingly.

### Schedule of Limitations pertaining to Issue 2 of this certificate:

There are no changes to the Schedule of Limitations.

### Drawings Associated with the Issue 2 of this Certificate:

There are no drawings applicable to this issue of the certificate.